

Registration Schedule

Establishment

Al Mashaan Steel Co

Address

South Subhan Industrial Zone
Block 9, Building 49, Street 101,
PO Box 2656
Salmiya 22027
Kuwait

Scope

Assessment/ Test Report	Doorset Description	Rating	Test Type
WF415508	M Steel 1 - Steel Door with Honeycomb Core (glazed/unglazed)	120min	BS 476 part 22
WF415509	M Steel 1 - Scope of application for steel doors with Rockwool Core (unglazed only)	120/180/240 min	BS 476 part 22
Chilt/A12011 Rev A	M Steel 1 – Latched Double Leaf Single Acting Steel doorset (unglazed only)	120min	BS 476 part 22
BMT/FEP/F14040	M Steel 2 - Double Leaf Single Acting Steel Doorset (unglazed only)	240 min	BS 476 part 22
WF400324	M Steel 1 - Single Leaf Single Acting Steel doorset with glazing	30 min	BS 476 part 22
WF393286	M Steel 1 - Single Leaf Single Acting Steel doorset with glazing	60 min	BS 476 part 22
Chilt/RF11156 Rev A	M Steel 2 - Double Leaf Single Acting Doorset (unglazed only)	120 min	BS 476 part 22
BMT/FEP/F14043	M Steel 2 - Glazed Double Leaf Single Acting Steel Doorset	120 min	BS 476 part 22